

Rule No. 2

DESCRIPTION OF SERVICE

A. Quantities

The Utility will endeavor to supply water dependably and safely in adequate quantities to meet the reasonable needs and requirements of customers.

B. Pressures

1. Generally

The Utility will endeavor to maintain normal operating pressures of not less than 40 pounds per square inch nor more than 125 pounds per square inch at the service connection, except that during periods of hourly maximum demand the pressure at the time of peak seasonal loads may not be less than 30 pounds per square inch and that during periods of hourly minimum demand the pressure may not be more than 150 pounds per square inch. Variations in pressure under normal operation will not exceed 50% of the average operating pressure. (The average operating pressure will be determined by computing the arithmetical average of at least 24 consecutive hourly pressure readings.)

2. Designated Pressure Area

Within designated areas as shown or described on Utility's service area map, the Utility will endeavor to maintain normal minimum operating pressure between 25 p.s.i.g. and 40 p.s.i.g. with peak load pressures above 20 p.s.i.g. Prior to June 5, 1976, inquiry should be made to the Utility for location of such designated areas.

C. Quality

Whenever furnished for human consumption or for domestic uses, the Utility will endeavor to provide water that is wholesome, potable, in no way harmful or dangerous to health and, insofar as practicable, free from objectionable odors, taste, color and turbidity.

Advice Letter No. 209-W

Daniel M. Conway

Name

Vice President

Title